

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

REQUEST OF GRAYSON RURAL ELECTRIC)	
COOPERATIVE CORPORATION TO DEVIATE)	CASE NO. 2008-00305
FROM 807 KAR 5:041, SECTION 15(3),)	
PERIODIC TESTING OF SINGLE PHASE METERS)	

O R D E R

On September 2, 2008, Grayson Rural Electric Cooperative Corporation ("Grayson") petitioned for withdrawal of its request for a deviation from the periodic testing of single phase meters as required under 807 KAR 5:041, Section 15(3). Currently, Grayson reads its meters every 3 years. Grayson had sought the Commission's approval to test its meters every 9 years instead of every 8 years to coordinate more efficiently with its 3-year meter reading program. In its request to withdraw its application, Grayson states that it is reevaluating its testing program and will file a new deviation request in the near future.


Having reviewed the motion and being otherwise sufficiently advised, the Commission finds that Grayson's request to withdraw its application should be granted.

IT IS THEREFORE ORDERED that:

1. Grayson's request is granted.
2. This case is closed and is removed from the Commission's docket.

Done at Frankfort, Kentucky, this 12th day of September, 2008.

By the Commission

ATTEST:

Executive Director